

General conditions of acceptance and explanation of the information given in the list

- 1 The component(s) offered for acceptance shall be identical to the sample(s) submitted in support of and/or described in the application.
- 2 The component(s) shall be installed in accordance with the by-laws of the relevant local authority, water service provider and the relevant SABS Code of Practice.
- 3 This list shall not be used for advertising purposes.
- 4 Inclusion of a component(s) in this list does not in any way imply endorsement of such product(s) by JASWIC.
- 5 The line number in column 1 refers only to this issue of the list. When making an enquiry, please quote the date of issue of the list in addition to the line number in order to positively identify the component concerned.
- 6 <<Mark>> in column 6 indicates that the article shall bear the SABS mark <<Comply>> indicates that the article, although not bearing a standards mark, shall comply with all the requirements of the specification quoted in column 5.
- 8 Components accepted for use in irrigation systems only shall be installed downstream of an accepted isolating valve and backflow prevention device.
- 9 Components accepted for use in fire installations shall be capable of withstanding a hydraulic pressure test of 2 000kPa for a period of not less than 5 minutes without showing signs of leakage.
- 10 Any reference to <<brazing>> in the list shall, unless otherwise stated, be taken to include hard soldering at temperatures exceeding 300 degrees Celsius.
- 11 Please note that certain local authorities, which allow a maximum cistern capacity of only 9,5 litres, may allow larger capacities for replacement purposes only.
- 12 Jaswic reserves the right to inform the public of any fraudulent claims made by any manufacturer/applicant.
- 13 The catalogue reference indicated in the JASWIC Acceptancy List does not imply that all products listed in the catalogue/range are necessarily accepted by JASWIC.