

JASWIC LISTING PROCEDURE

A Products bearing the SABS Mark

- A.1** Complete the JASWIC application form (download JASWIC application form at www.jaswic.co.za), attach all required information and forward it to JASWIC along with all the supporting information and a copy of the current and valid SABS Mark certificate and Schedule. The Mark Certificate Schedule must include all relevant information pertaining to sizes, types, pressure classes and other identifying descriptions. Enough information should be supplied to enable accurate identification of the components. JASWIC may also request the submission of identification visuals (a photograph of each item/component being submitted for listing), as well as full SABS test reports (against the current SANS standard). For components/systems where DZR results are required in accordance with the relevant SANS specification for the product being tested, a separate and detailed DZR test report from a SANAS accredited laboratory is required in accordance with SANS 6509. This test report must reference the specific sample (ie, full description of sample) being tested and must include a chemical composition analysis in accordance with SANS 1303/SANS 200.
- A.2** The applicant will receive an acknowledgement of receipt and the application will be tabled at the next JASWIC acceptance meeting.
- A.3** The committee will verify the details with mark-holders and the SABS. The application is logged onto the JASWIC database as “pending” until queries are resolved.
- A.4** If the application is approved, proof of electronic payment of the R500.00 acceptance administration fee is required. The components will be listed as “Accepted” and the committee will send the applicant a notice of acceptance and of listing as “Mark” bearing and will also issue a JASWIC certificate (if required) which has the same expiry date as the SABS Mark certificate.

NOTES (SABS Mark Scheme listings):

Refer to the SABS (www.sabs.co.za) for information on the SABS Mark Certification Scheme for the procedure to apply the SABS Mark of approval to water installation products.

The applicant shall only be entitled to claim JASWIC acceptance of any product that is currently JASWIC listed and has a current and valid SABS Mark (Permit) certificate, and may apply to such product any statement, JASWIC logo or any other indication of JASWIC acceptance listing.

When components are removed from the JASWIC acceptance list for any reason, or when such components no longer carry the SABS Mark, the applicant must immediately discontinue any references implying current JASWIC acceptance on stationary, advertising and sales material, displays, websites, contract documents etc. Failing that, JASWIC would have to advise the industry and the public that the components are no longer JASWIC listed and that any implied or explicit claims of ongoing JASWIC acceptance are false. This may take the form of listing such warnings on the JASWIC website and/or publishing the warnings in the appropriate trade magazines.

B1 Products NOT bearing the SABS Mark (JASWIC “Comply” listing)

- B1.1** The applicant must contact the SABS or other SANAS accredited certification body to determine the relevant SANS standards which apply to the component or system which is to be submitted for acceptance listing. Arrange with the SABS or other SANAS accredited testing laboratory for the required tests and reports for JASWIC application

for either single items, full or partial ranges or systems. The SABS or other SANAS accredited body will collect samples and select appropriate representative items for the tests. Full specification test reports not older than one year (against the current SANS standard) are required. For Acceptance listing, JASWIC will only evaluate the products/range of products and/or diameters submitted for testing to the accredited SANAS accredited testing laboratory. Should only single items or partial ranges be submitted, JASWIC will only evaluate these specific components for JASWIC listing.

For components/systems where DZR results are required in accordance with the relevant SANS specification for the product being tested, a separate and detailed DZR test report from a SANAS accredited laboratory is required in accordance with SANS 6509. This test report must reference the specific sample (ie, full description of sample) being tested and must include a chemical composition analysis in accordance with SANS 1303/SANS 200.

Test reports shall include details of the markings on the products, and photographs clearly indicating the various markings shall be included in the test reports for identification purposes.

- B1.2** The applicant shall send a fully completed application form (download JASWIC application form from www.jaswic.co.za), attaching full SABS or other SANAS accredited body's test reports (not older than one year) and all other required substantiating product and technical information including relevant brochures. JASWIC may also request the submission of identification visuals (a photograph of each item/component being submitted for listing), samples, sales item numbers and descriptions, installation instructions, warnings and restrictions etc., which would enable the correct identification of the components and its intended application in terms of installation regulations.
- B1.3** The applicant will receive an acknowledgement of receipt and the application will be tabled at the next JASWIC acceptance meeting.
- B1.4** The committee shall check and confirm submitted details with applicants (if required) and the SABS or other SANAS accredited body. The application is logged onto the system as "pending" until queries (if any) are resolved.
- B1.5** If the application is approved, proof of electronic payment of the R1500.00 acceptance administration fee is required. The product will then be listed as complying with the relevant specifications ("Comply" on the JASWIC listing) and a JASWIC certificate valid for two years from the date of acceptance will be issued. The validity of the certificate and the continued listing of the component will be subject to continued compliance.
- B1.6** In order to maintain continued JASWIC acceptance listing, renewal applications must be done at least 2 months before the expiry date, subject to the same conditions as for new applications.

NOTES (JASWIC Comply listings):

The applicant shall only be entitled to claim JASWIC acceptance of any product that is currently JASWIC accepted and listed, and may apply to such product any statement, JASWIC logo or any other indication of JASWIC acceptance listing.

The applicant shall inform JASWIC of any change in the manufacturer, method of manufacture, material used, design or components. In the event of such change(s) JASWIC may, at its discretion, demand the submission of fresh evidence of conformity to the relevant specification(s) and/or a new application for product listing may be requested.

Should the listing be terminated for any reason, it will be removed from the JASWIC acceptance list, and the applicant must immediately discontinue any references implying current JASWIC acceptance, on stationery, advertising and sales material, displays, websites, contract documents etc. Failing that, JASWIC would have to advise the industry

and the public that the product is no longer on the JASWIC acceptance list, and that any claims or inference of JASWIC acceptance are false. This may take the form of listing the warning on the JASWIC website and/or by publishing the warnings in the appropriate trade magazines.

Version 22/05/a